

**Tactical Water Tender PRE-USE Inspection Form PASS FAIL**

<b>Company Name:</b>		<b>Date:</b>		Page 1 of 2
<b>Vehicle Identification</b>		<b>Odometer Reading</b>		
NWCG Type Tactical Water Tender (1-3):		Allowable Tank Capacity (gallons)		
VIN #:				
License #:		State:		
Make:		Model:		Year:
<b>All Wheel Drive</b>		<b>Yes</b>	<b>No</b>	
<b>Markings Posted on Vehicle</b> (annotate actual posting)		<b>Yes</b>	<b>No</b>	
Company Name:				
Unit ID #:				
DOT #:				
<b>Vehicle Licensing</b>				
Vehicle meets licensing requirements		<b>Yes</b>	<b>No</b>	
Vehicle meets CVSA requirements (optional)		<b>Yes</b>	<b>No</b>	
<b>Minimum Tender Inventory</b>		<b>Satisfactory?</b>		
		<b>Yes</b>	<b>No</b>	<b>Qty</b>
1 - live Hose Reel min. 100' of 1" hose non-collapsible w/3/4" inside diameter				
1 - Handheld Programmable Radio				
1 - 1 1/2" nozzle NH combination fog/straight stream				
1 - Nozzle, Class A Foam, 1 1/2" NH Female, Min. 20 GPM at 100 psi				
2 - Shovels, size 0 or 1				
2 - Pulaskis				
1 - Spanner Wrench, combination 1 1/2" to 2 1/2"				
1 - Adjustable Hydrant Wrench				
2 - Adapters 1 1/2" NPSH Female to 1 1/2" NH Male				
2 - Adapters 1 1/2" NH Female to 1 1/2" NPSH Male				
2 - Reducers 2 1/2" NH Female to 1 1/2" NH Male				
1 - Reducer, 1 1/2" NH Female to 1" NPSH Male				
1 - Double Male 1 1/2" NH				
1 - Double Female 1 1/2" NH				
1 - Gated Wye 1 1/2" NH				
1 - Fire Hose Clamp 2 1/2"				
200' - 1 1/2" cotton/synthetic hose NH thread				
50' - 2 1/2" cotton/synthetic hose NH thread				
10 - Fusee's (fire starter)				
2 - Line Gear (day Pack)				
<b>Pump</b> (check one)				
PTO		Auxiliary		
Fuel to operate pump for 12 hours (If Auxiliary Pump)		<b>Yes</b>	<b>No</b>	
20' Suction hose w/strainer or screened foot valve		<b>Yes</b>	<b>No</b>	
<b>Pressurized Discharge Outlets</b>		<b>Yes</b>	<b>No</b>	
1 - 2 1/2" NH				
2 - 1 1/2" NH				
Amount of Foam on Tender (min. 5 gal)				
Reflective Triangles, bi-directional, set of 3				
Fire Extinguisher, 1 rated at 2A 10 B:C or better				
1 - First Aid Kit (5 person)				
2 - each Wheel chocks				
Seat belts for all passengers				
Tank meets baffling requirements				
4" Dump Valve at bottom of tank ( min. 34" from round)				
2 1/2" valve at bottom of tank with NH hose threads				

